

Wisconsin Department of Safety and Professional Services  
Division of Industry Services  
1400 East Washington Avenue  
PO Box 2658  
Madison WI 53701-2658



Phone: 608-266-2112  
Web: <http://dsps.wi.gov>  
Email: [dsps@wisconsin.gov](mailto:dsps@wisconsin.gov)

**Scott Walker, Governor**  
**Dave Ross, Secretary**

---

### **Boiler & Combustion Hazard Codes Q&As**

**1. Does Wisconsin require conformance to NFPA 85 "Boiler and Combustion Systems Hazards Codes"? (NFPA 85 applies to industrial boiler-furnaces and associated ducts.)**

**Answer:** No, Wisconsin does not adopt or mandate NFPA 85, but it can be used for the gas train installations.